

JDYX2.E126056  
Fuses, Supplemental - Component

[Page Bottom](#)

Fuses, Supplemental - Component

[See General Information for Fuses, Supplemental - Component](#)

**ORISEL CO LTD**

E126056

394-5 KOCHUN-DONG

EUIWANG-SHI, KYONGGI-DO 437-010 REPUBLIC OF KOREA

Cat. No.	Size	Amps	V ac	Interrupting Rating (kA)
N51, N52+	20MM X 5.2MMOD	4.0-8.0	125, 250	0.100
S51, S52+	20MM X 5.2MMOD	4.0-8.0	125, 250	0.100
65TL	31.8MM X 6.35MMOD	16-30	125, 250	10, 0.200
55F	20MM X 5.2MMOD	1-6.3	250	1.5
55T	20 mm x 5.2 mm OD	1 - 6.3, 8, 9, 10	250	1.5
56F+	21 mm x 5.5 mm OD	1 - 6.3	250	1.5
56T+	21 mm x 5.5 mm OD	1-6.3, 8, 9, 10	250	1.5
50F, 52F+	20MMX5.2MMOD	0.2-3.15	250	0.035
		3.15-6.3	250	0.063
50T, 52T+	21MMX5.7MMOD	0.2-1.0	250	0.035
		1.25-6.3	250	0.063
N65	31.8MMX6.35MMOD	6.0 -20.0	125, 250	10, 0.200
<b>Microfuses:</b>				
OR5	—	0.5-3.15, 5, 6.3, 8	250	0.035
		4	250	0.040
OS5	—	0.5-6.3	250	0.050
OCQ3216	—	1 - 2.0	63, 32, 24 Vac	0.06
			63, 32, 24 Vdc	0.06
		2.5 - 4.0	32, 24 Vac	0.07
			32, 24 Vdc	0.07

+ - Pigtail leads.

++ - Time delay.

Marking: Company name and catalog designation.

[Last Updated](#) on 2010-12-07

[Questions?](#)

[Print this page](#)

[Notice of Disclaimer](#)

[Page Top](#)

[Copyright • 2010 Underwriters Laboratories Inc.®](#)

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Listed and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Designs and/or Listings (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from Underwriters Laboratories Inc." must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "Copyright © 2010 Underwriters Laboratories Inc.®"

JDYX8.E126056  
Fuses, Supplemental Certified for Canada - Component

[Page Bottom](#)

Fuses, Supplemental Certified for Canada - Component

[See General Information for Fuses, Supplemental Certified for Canada - Component](#)

**ORISEL CO LTD**

E126056

394-5 KOCHUN-DONG

EUIWANG-SHI, KYONGGI-DO 437-010 REPUBLIC OF KOREA

**Miniature, Cartridge enclosed, nonrenewable:**

Cat. No.	Size	Amps	V ac	Interrupting Rating (kA)
N51, N52+	20MM X 5.2MMOD	4.0-8.0	125, 250V	0.100
S51, S52+	20MM X 5.2MMOD	4.0-8.0	125, 250V	0.100
50F, 52F+	20MM X 5.2MMOD	0.2-3.15	250	0.035
		3.15-6.3	250	0.063
50T, 52T+	21MM X 5.7MMOD	0.2-1.0	250	0.035
		1.25-6.3	250	0.063
55F	20 mm x 5.2 mm OD	1-6.3	250	1.5
55T	20 mm x 5.2 mm OD	1-6.3, 8, 9, 10	250	1.5
56F+	21 mm x 5.5 mm OD	1 - 6.3	250	1.5
56T+	21 mm x 5.5 mm OD	1-6.3, 8, 9, 10	250	1.5
65TL	31.8 mm x 6.35 mm OD	16-30	125/250	10, 0.200
N65	31.8 mm X 6.35 mm OD	6.0-20.0	125, 250	10, 0.200

**Microfuses:**

Cat. No.	Size	Amps	V ac	Interrupting Rating (kA)
OS5		0.5-6.3	250	0.05
<b>OR5</b>		<b>0.5-3.15, 5, 6.3, 8</b>	<b>250</b>	<b>0.035</b>
		<b>4.0</b>	<b>250</b>	<b>0.040</b>
OCQ3216	—	1 - 2.0	63, 32, 24 Vac	0.06

	63, 32, 24 Vdc	0.06
2.5 - 4.0	32, 24 Vac	0.07
	32, 24 Vdc	0.07

+ - Pigtail leads.

++ - Time delay.



Marking: Company name, catalog designation and Recognized Component Mark of Canada

[Last Updated](#) on 2010-12-07

[Questions?](#)

[Print this page](#)

[Notice of Disclaimer](#)

[Page Top](#)

[Copyright • 2010 Underwriters Laboratories Inc.®](#)

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Listed and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Designs and/or Listings (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from Underwriters Laboratories Inc." must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "Copyright © 2010 Underwriters Laboratories Inc.®"